



Ref. Certif. No.

JPTUV-169867

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	High Voltage Energy Storage Module
Name and address of the applicant	Midcosta s.r.o. Priemysel'na 8E, 91701 Trnava Slovakia
Name and address of the manufacturer	Midcosta s.r.o. Priemysel'na 8E, 91701 Trnava Slovakia
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Jiangmen zetara power technology Co., LTD No. 32, Yixing Road, Jianghai District, Jiangmen City, Guangdong, P.R. China
Ratings and principal characteristics	350-435V; 7.5A; 3KW
Trademark / Brand (if any)	N/A
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	MID-HV5
Additional information (if necessary may also be reported on page 2)	N/A
A sample of the product was tested and found to be in conformity with	IEC 62619:2022
As shown in the Test Report Ref. No. which forms part of this Certificate	CN254N8Y 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland Japan Ltd.
4-25-2 Kita-Yamata, Tsuzuki-ku
Yokohama 224-0021, Japan
Mail: info@jpn.tuv.com

Date: 2025-02-17

Signature:

Dean Cao

10/061SMD 2024-12 rke-simplified